ROLLED STEEL ODP AEGIS® SGR

ASGHPE, NEMA PREMIUM WITH AEGIS® SGR [DTP_G]

Effective 07-08-18 Supercedes 03-24-17

(CC002A (Mus (E



APPLICATIONS:

- Fans & Blowers
- Pumps
- Compressors
- HVAC Equipment

The AEGIS[®] SGR Bearing Protection Ring aids in preventing electrical bearing "fluting"damage by safely diverting harmful shaft voltages and bearing currents to ground. Using proprietary Electron Transport Technology[™], the conductive microfibers inside the AEGIS[®] SGR provide reliable current diversion technology for shaft grounding with a "path of least resistance" to dramatically extend motor life. **AEGIS[®] Shaft Grounding Rings have a warranty of 1 year.**

FEATURES:

- Output Range: 1 40 HP
- Speed: 3600, 1800 & 1200 RPM
- Enclosure: Open Drip Proof (IP22)
- Voltage: 230/460V (Usable on 200 & 208V)
 - Three Phase, 60 Hz, 1.15 Service Factor (Continuous); 50 Hz, 1.0 Service Factor (Continuous)
- Grounding Ring Factory Installed Externally on DE Bracket
- Class F Insulation
- NEMA Design B Torques
- Rolled Steel Frame and Main Conduit Box
- Grounding Terminal Inside Main Conduit Box
- Oversized Main Conduit Box Rotatable in 90 Degree Increments F1 Mounted
- Designed for 40°C Ambient Temperature⁽¹⁾
- Designed for 3300 ft. Elevation⁽²⁾
- Bi-Directional Rotation
- 1045 Carbon Steel Shaft
- Aluminum Die Cast Squirrel Cage Rotor Construction
- Paint System: Phenolic Rust Proof Base Plus Polyurethane Top Coat
- Paint Color: Blue Munsell 5PB 3/8
- Double Shielded Bearings Pre-Packed with MULTEMP SRL (Non-regreasable)
- Stainless Steel Nameplate
- New Dual Column Design Nameplate as Standard (60/50 Hz)
- Suitable for Inverter Use per NEMA MG-1.4.4.2, Part 31^(3,4)
- Inverter Duty Speed Range: 20:1 Variable Torque, 10:1 Constant Torque
- 9 Leads for 5 HP and Smaller;
- 12 Leads for 7.5 HP and Larger
- Motors are U.L. Recognized for United States and Canada, CSA Approved and CE Marked

EXTRAS/ OPTIONS:

Please refer to the modifications document for common modifications that can be performed.

Notes:

- (1) Consult a Stock Product Application Specialist for suitability in higher ambient environments.
- (2) Consult a Stock Product Application Specialist for suitability at higher elevations.
- (3) Motor service factor is 1.0 when operated on a VFD.
- (4) Precautions should be taken to eliminate or reduce shaft currents that may be imposed on the motor by the VFD as stated per NEMA MG-1. Part 31.
- (5) AEGIS® SGR Bearing Protection Ring can not be used in Hazardous Locations (i.g. Class I, Div. 2, etc.)

